



EC type-examination certificate
EG-Baumusterprüfbescheinigung
Attestation d'examen CE de type

Certification No.: 08/208/AP 003/01

Notified Office: TÜV CERT Certification body of the
TÜV Hannover/Sachsen-Anhalt e.V.,
Ident. No.: 0032

Certificate owner: Henning GmbH
Loher Straße 30
D-58332 Schwelm

Date of application: 2000-09-14

Manufacturer: See Certificate owner

Product, type: Hydraulic lift buffer
LP 40 x 80

Test laboratory: Test laboratory for safety of technical systems

Date and number of test report: 00/PM20300 dated 2000-12-08

EU Directive: Lift directive 95/16/EC

Test result: The safety component satisfies the basic safety and health requirements of the Directive indicated for the field of application as specified in the annex on page 1 of this type-examination certificate.

Date of issue: 2000-12-08

TÜV CERT-Zertifizierungsstelle
für Maschinen, Aufzugs- und Fördertechnik
des TÜV Hannover/Sachsen-Anhalt e.V.

Head of the
Certification Body

A handwritten signature in black ink, appearing to be 'R. Rosin'.

(Rosin)



DAR-Reg.-No.: ZLS-ZE-136/97
Ident. No. of the notified body: 0032

Annexe to the EC type-examination certificate No. 08/208/APH 003/01, 1 page



Annex to the EC type-examination certificate No. 08/208/AP 003/01

1. Required information
 - 1.1 Hydraulic lift buffer LP 40 x 80
 - 1.2 Field of application: for use with lifts in accordance with directive 95/16/EC
 - 1.3 Maximum nominal speed: 1 m/s
 - 1.4 Maximum mass: 3000 kg
 - 1.5 Minimum mass: 450 kg
 - 1.6 For the selection of the types of oils and the dimensions see the operation manual of the manufacturer (version 1.6 dated 2000-08-22)
2. Note:

The EC type-examination certificate must be used together with the corresponding appendix only.

Hanover, 2000-12-08

EC-declaration of conformity

We hereby declare, the company

Henning GmbH
Loher Str. 30
58332 Schwelm

that the following product meets the safety and health requirements of the EC-directive due to its concept, construction and the type approval.

This declaration becomes invalid if a construction change is not coordinated with us.

Product: Lift buffer, model LP

Type LP 40 x 80	Year of construction	:	see type label
	Series No.	:	see marking on buffer
Type LP 40 x 120	Year of construction	:	see type label
	Series No.	:	see marking on buffer
Type LP 40 x 175	Year of construction	:	see type label
	Series No.	:	see marking on buffer
Type LP 40 x 275	Year of construction	:	see type label
	Series No.	:	see marking on buffer
Type LP 50 x 425	Year of construction	:	see type label
	Series No.	:	see marking on buffer
Type LP 50 x 695	Year of construction	:	see type label
	Series No.	:	see marking on buffer

EC-directive: EC lift directive 95/16/EG
EC low voltage directive 73/23/EWG, version 93/68/EWG

Used harmonized standards:

EN 81-1, EN 81-2: Safety regulation for the construction and installation of lifts
EN 60204 part 1: Electrical installations at machines

Schwelm, 09.01.2001



Henning GmbH

(Dirk Henning, Geschäftsführer)